§ 3280.204

- (iii) ⁵/₁₆-inch or thicker unfinished gypsum wallboard (both latex- or alkyd-painted); and
 - (iv) Ceramic tile.

(The above-listed material applications do not waive the requirements of §3280.203(c) or §3280.204 of this subpart.)

- (b) Flame-spread rating requirements.
- (1) The interior finish of all walls, columns, and partitions shall not have a flame spread rating exceeding 200 except as otherwise specified herein.
- (2) Ceiling interior finish shall not have a flame spread rating exceeding 75.
- (3) Walls adjacent to or enclosing a furnace or water heater and ceilings above them shall have an interior finish with a flame spread rating not exceeding 25. Sealants and other trim materials 2 inches or less in width used to finish adjacent surfaces within these spaces are exempt from this provision provided that all joints are completely supported by framing members or by materials having a flame spread rating not exceeding 25.
- (4) Exposed interior finishes adjacent to the cooking range shall have a flame spread rating not exceeding 50, except that backsplashes not exceeding 6 inches in height are exempted. Adjacent surfaces are the exposed vertical surfaces between the range top height and the overhead cabinets and/or ceiling and within 6 horizontal inches of the cooking range. (Refer also to §3280.204(a), Kitchen Cabinet Protection.) Sealants and other trim materials 2 inches or less in width used to finish adjacent surfaces are exempt from this provision provided that all joints are completely supported by a framing member.
- (5) Kitchen cabinet doors, countertops, backsplashes, exposed bottoms, and end panels shall have a flame spread rating not to exceed 200. Cabinet rails, stiles, mullions, and top strips are exempted.
- (6) Finish surfaces of plastic bathtubs, shower units, and tub or shower doors shall not exceed a flame spread rating of 200.
 - (c) Fire protective requirements.
- (1) Materials used to surface the following areas shall be of limited com-

bustible material (e.g., 5/16-inch gypsum board, etc.):

- (i) The exposed wall adjacent to the cooking range (see § 3280.203(b)(4));
- (ii) Exposed bottoms and sides of kitchen cabinets as required by § 3280.204;
- (iii) Interior walls and ceilings enclosing furnace and/or water heater spaces; and
- (iv) Combustible doors which provide interior or exterior access to furnace and/or water heater spaces. The surface may be interrupted for louvers ventilating the enclosure. However, the louvers shall not be constructed of a material of greater combustibility than the door itself (e.g., plastic louvers on a wooden door).
- (2) No burner of a surface cooking unit shall be closer than 12 horizontal inches to a window or an exterior door with glazing.

[49 FR 32008, Aug. 9, 1984, as amended at 58 FR 55005, Oct. 25, 1993; 70 FR 72042, Nov. 30, 2005]

§ 3280.204 Kitchen cabinet protection.

- (a) The bottom and sides of combustible kitchen cabinets over cooking ranges to a horizontal distance of 6 inches from the outside edge of the cooking range shall be protected with at least 5/16-inch thick gypsum board or equivalent limited combustible material. One-inch nominal framing members and trim are exempted from this requirement. The cabinet area over the cooking range or cooktops shall be protected by a metal hood (26-gauge sheet metal, or .017 stainless steel, or .024 aluminum, or .020 copper) with not less than a 3-inch eyebrow projecting horizontally from the front cabinet face. The 5/16-inch thick gypsum board or equivalent material which is above the top of the hood may be supported by the hood. A %-inch enclosed air space shall be provided between the bottom surface of the cabinet and the gypsum board or equivalent material. The hood shall be at least as wide as the cooking
- (b) The 3-inch metal eyebrow required by paragraph (a) of this section will project from the front and rear cabinet faces when there is no adjacent surface behind the range, or the 5/6-inch thick gypsum board or equivalent

Office of Asst. Sec. for Housing, HUD

material shall be extended to cover all exposed rear surfaces of the cabinet.

- (c) The metal hood required by paragraphs (a) and (b) of this section can be omitted when an oven of equivalent metal protection is installed between the cabinet and the range and all exposed cabinet surfaces are protected as described in paragraph (a) of this section
- (d) When a manufactured home is designed for the future installation of a cooking range, the metal hood and cabinet protection required by paragraph (a) of this section and the wall-surfacing protection behind the range required by §3280.203 shall be installed in the factory.
- (e) Vertical clearance above cooking top. Ranges shall have a vertical clearance above the cooking top of not less than 24 inches to the bottom of combustible cabinets.

EFFECTIVE DATE NOTE: At 78 FR 73982, Dec. 9, 2013, §3280.204 was amended by revising paragraph (c), effective June 6, 2014. For the convenience of the user, the revised text is set forth as follows:

§3280.204 Kitchen cabinet protection.

* * * * * *

- (c) Alternative compliance. When all exposed surfaces along the bottoms and sides of combustible kitchen cabinets are protected as described in paragraph (a) of this section, the metal hood, the 5/16-inch thick gypsum board or equivalent material, and the 3%-inch airspace required by paragraph (a) of this section can be omitted, provided that:
- (1) A microwave oven is installed between the cabinet and the range; and
- (2) The microwave oven is equivalent in fire protection to the metal range hood required by paragraph (a) of this section; and
- (3) The microwave oven is certified to be in conformance with Microwave Cooking Appliances, UL 923-2002 (incorporated by reference, see § 3280.4).

* * * * *

§ 3280.205 Carpeting.

Carpeting shall not be used in a space or compartment designed to contain only a furnace and/or water heater. Carpeting may be used in other areas where a furnace or water heater is installed, provided that it is not located under the furnace or water heater.

§ 3280.206 Fireblocking.

- (a) *General*. Fireblocking must comply with the requirements of this section. The integrity of all fireblocking materials must be maintained.
- (b) Fireblocking materials. Fireblocking must consist of the following materials:
- (1) Minimum one inch nominal lumber, 5/16 inch thick gypsum board, or equivalent fire resistive materials; or
- (2) Other Listed or Approved Materials:
- (c) Fireblocking locations. (1) Fireblocking must be installed in concealed spaces of stud walls, partitions, and furred spaces at the floor and ceiling levels. Concealed spaces must not communicate between floor levels. Concealed spaces must not communicate between a ceiling level and a concealed roof area, or an attic space.
- (2) Fireblocking must be installed at the interconnection of a concealed vertical space and a concealed horizontal space that occurs:
- (i) Between a concealed wall cavity and the ceiling joists above; and
- (ii) At soffits, drop ceilings, cover ceilings, and similar locations.
- (3) Fireblocking must be installed around the openings for pipes, vents, and other penetrations in walls, floors, and ceilings of furnace and water heater spaces. Pipes, vents, and other penetrations that cannot be moved freely within their opening are considered to be fireblocked. Materials used to fireblock heat producing vent penetrations must be noncombustible or limited combustible types.

[71 FR 72042, Nov. 30, 2005]

§ 3280.207 Requirements for foam plastic thermal insulating materials.

- (a) General. Foam plastic thermal insulating materials shall not be used within the cavity of walls (not including doors) or ceilings or be exposed to the interior of the home unless:
- (1) The foam plastic insulating material is protected by an interior finish of 5/16-inch thick gypsum board or equivalent material for all cavities where the material is to be installed; or
- (2) The foam plastic is used as a sheathing or siding backerboard, and it: